

CERTIFICATE

According to "Certification regulations Product Certification"
Svensk Brand- och Säkerhetscertifiering AB, Tegelluddsvägen 100, 115 28 Stockholm, Sweden

No 10-581

Electromechanically operated lock and striking plates
Exma Rapid

Fulfils the requirements according to
EN 14846:2008

Classification								
1	2	3	4	5	6	7	8	9
Category of use	Durability and load on latch bolt	Door mass and closing force	Suitability for use on fire/smoke doors	Safety	Corrosion resistance, temperature and humidity	Security and drill resistance	Security electrical function	Security electrical manipulation
3	C	0	D	0	M	5	1	3

This certificate do not include EN 14846 Annex ZA regarding CE marking.

Certificate holder is

Exma Säkerhetssystem AB

Filargatan 6 , Eskilstuna

Certificate is valid

2021-12-17 until 2025-12-31

Stockholm 2021-12-17



Mårten Wallén
Managing Director