

CERTIFICATE

According to "Certification regulations Product Certification"
Svensk Brand- och Säkerhetscertifiering AB, Tegeluddsvägen 100, 115 28 Stockholm, Sweden

No 20-515

Electromechanically operated lock and striking plates Exma Compact

Fulfils the requirements according to
EN 14846:2008

Classification								
1	2	3	4	5	6	7	8	9
Category of use	Durability and load on latch bolt	Door mass and closing force	Suitability for use on fire/smoke doors	Safety	Corrosion resistance, temperature and humidity	Security and drill resistance	Security electrical function	Security electrical manipulation
3	C	0	D	0	M	5	1	0

This certificate do not include EN 14846 Annex ZA regarding CE marking.

Certificate holder is
Exma Säkerhetssystem AB
Filargatan 6 , Eskilstuna

Certificate is valid
2021-01-13 until 2026-01-12

Stockholm 2021-01-13



Mårten Wallén
Managing Director